

21

NO. 6 FUEL OIL 1.50%

EX. SHORE TANK NO. 1 AFTER DISCHARGE OF BERTHEA
INSPECTORATE
INSPECTORATE

GRAVITY, API @ 60 F	ASTM D 4052	11.6
FLASH POINT, F	ASTM D 93	200+
VISCOSITY, SSF @ 122 F	ASTM D 445/2161	288
POUR POINT, F	ASTM D 97	+33.8
WATER & SEDIMENT, % VOL.	ASTM D 1796	0.20
ILPHUR, % WT.	ASTM D 4294	1.488
SH, % WT.	ASTM D 482	0.034
VANADIUM, PPM	AA/AE	117
SODIUM, PPM	AA/AE	9
BTU'S/POUND	CALCULATION	18,363
BTU'S/GALLON	CONVERSION	151,219
NITROGEN, % WT.	ASTM D 3228	0.437
CARBON RESIDUE, % WT.	ASTM D 4530	12.91
ASPHALTENES, % WT.	IP-143	7.44

THE ATTACHED CERTIFICATE REPRESENTS THE PRODUCT INSPECTED BY THE INSPECTION SERVICE ON THE DATE STATED ON THE CERTIFICATE IN THE TANK STATED BY THE INSPECTION SERVICE. SPRAGUE REPRESENTS THAT ANY PRODUCT IT MAY SELL AT THE RACK MAY DIFFER FROM SUCH INSPECTION CERTIFICATE BUT SUCH PRODUCT SHALL MEET THE SPECIFICATIONS AS MAY BE REQUIRED BY ANY APPLICABLE REGULATIONS WITHIN THE STATE THAT THE PRODUCT IS SOLD.

SPLAB REV 1-98

DENNIS E. CURTIS
Inspectorate America Corp (Searsport, Me.)